12/23/11 Code: A-20

AMIETE - ET (OLD SCHEME)

Code: AE10 Time: 3 Hours			Subject: ELECTRICAL ENGINEERING Max. Marks: 100		
• Qu an • Ou	c: There are 9 Questions inestion 1 is compulsory and carrious are book supplied and nowhere t of the remaining EIGHT Quest				
Q.1	Choose the correct or the best	alternative in the following:	(2×10)		
a.	Copper losses at full load operation are 1600 W. If the load on the transformer is reduced to 75% of full load, the copper losses will be				
	(A) 1600 W (C) 900 W	(B) 1200 W (D) 800 W			
b.	At the instant of starting, the per unit slip of the 3-phase induction motor is				
	(A) 0.05 (C) 1.0	(B) 0.1 (D) 0.5			
c.	The commutator of dc motor serves the purpose of				
	(A) Changing ac into dc(C) Reducing friction	(B) Converting dc into ac(D) Avoiding arc at the brushe	S		
d.	In an ordinary transformer which of the following does not change				
	(A) Voltage(C) Frequency	(B) Current(D) All of the above			
e.	A 220 V dc shunt motor develops a torque of 54 Nm at an armature current of 10 A. The torque developed for the armature current of 20 A is				
	(A) 54 Nm (C) 108 Nm	(B) 81 Nm(D) None of the above			
f.	For a 3-phase 4 pole 50 Hz synchronous motor, the frequency, no. of poles and the load torque are all halved. The motor speed will be				
	(A) 375 rpm (C) 1500 rpm	(B) 75 rpm (D) 3000 rpm			

12/23/11 Code: A-20

g.	W	While starting a synchronous motor its field winding should be kept				
		Short circuit Connected to dc source	(B) Open(D) None of these			
h.		wound rotor induction motor can be duction motor by	distinguished from squirrel cage			
		Presence of slip-rings Shaft diameter	(B) Size of frame(D) None of these			
i.	Co	Control rods used in nuclear reactor made of				
	, ,	Zirconium Beryllium	(B) Boron (D) Lead			
j.	In	comparison with diesel power plant th	ne gas turbine power plant has			
		Lower overall thermal efficiency Same overall thermal efficiency	(B) Higher overall thermal efficiency(D) Unpredictable			
		•	TVE Questions out of EIGHT Questions. Ich question carries 16 marks.			
Q.2		a. Draw an approximate equivaregulation.	alent circuit of a transformer. Based upon it do (8)	erive the expression for its		
	b.	•	phase transformer is 98.77% when delivering full load ron losses and (ii) full load copper losses. (8)	ad at 0.8 p.f. and 99.13% a		
Q.3	a.	Explain with suitable diagram the c	construction details of a salient pole alternator.	(8)		
	b.	, 1	I motor has a synchronous reactance of 5π per pharation emf of 3600 V (line). Calculate the line of (8)	<u>*</u>		
Q.4	a.	Draw and explain load characteristics	s curve for various types of dc generator.	(8)		
	b.		0 rpm when taking a current of 25 A. The resistance necessary (8)			
Q.5	a.	Explain with the help of a diagram ho motor.	ow a rotating magnetic field is produced in the air ga (8)	up of 3-phase induction		

iete-elan.ac.in/qpjun10/AE10.htm

b. Write short notes on

12/23/11 Code: A-20

		(i) Torque-speed characteristics of 3-phase induction	n motor.	
		(ii) Application of 1-phase induction motors.	(8)	
Q.6		 a. Explain the construction and working principle (8) 	of a universal motor and mention it	s applications.
	b.	Describe the construction of hysteresis motor and sasynchronous speed of the rotor. (8)	how that it develops a running torque	both at synchronous and
Q. 7	ŧ	 a. Draw neat sketch of a thermal electric power p it. 	plant station and explain the function (8)	of major components in
	b.	What is wind energy? How can wind energy be conv	erted into electric energy?	(8)
Q.8	a.	Design precisely the 'Voltage Regulation' of a transmover factor. Can the regulation be negative? If so, u		dependence on the load
	b.	What do you understand by carrier current protection	n? Explain. (8)	
Q.9	a.	What are the advantages of electric heating? Give claccount of their working principles.	lassification of various electric heating (8)	methods along with brief
	b.	Write short technical notes on any TWO of the follow	ving:	
		(i) Lead Acid cell.(ii) Nickel Cadmium cell.		
		(iii) Button cell.	(4×2)	